



MID-TENN ENGINEERING COMPANY

JUL 06 2010

3/11/10 ✓
RMT ✓
RLH ✓

June 30, 2010

Tennessee Department of Environment and Conservation
Division of Water Pollution Control
L & C Tower, 6th Floor
401 Church Street
Nashville, Tennessee 37243-1534

RE: ENVIRONMENTAL REPORT
WATER DISTRIBUTION SYSTEM EXPANSION PROJECT
CITY OF LAFAYETTE, TENNESSEE

Dear Sirs:

The City of Lafayette is in the process of performing an environmental review pursuant to the National Environmental Policy Act for USDA, Rural Utilities Service in order that it may assess the environmental impacts of the proposed expansion of the current water distribution system in Macon County, Tennessee. This project will include the installation of a 12-inch diameter PVC water line along Highway 52 with a 500,000 gallon prestressed concrete ground storage tank constructed at the highest point on Cross Lanes Road. Enclosed is a U. S. Geological Survey map(s) and a soil map that depicts the proposed project's area of potential effect for all construction activities and a detailed description of the work involved.

We are requesting the assistance of your office in reviewing the proposed project as it pertains to **erosion control, stormwater management requirements, and issued NPDES permits**. Please provide any recommendations you may have to mitigate or avoid these impacts.

We would appreciate a response within 30 days. Should you have any questions or need additional information pertaining to this project, please contact me at (615) 666-2385 or e-mail ewhite@nctc.com.

Sincerely,

Evan White, Engineer

Enclosures

cc: Cookeville Environmental Assistance Center
1221 South Willow Avenue
Cookeville, TN 38506